SIEMENS

Data sheet 6EP1437-3BA20



SITOP PSU300B/3AC/24VDC/30A

**** spare part **** SITOP PSU300B 30 A stabilized power supply input: 400-500 V 3 AC output: 24 V DC/30 A successor: 6EP3437-8UB00-0AY0

input		
type of the power supply network	3-phase AC	
supply voltage at AC minimum rated value	400 500 V	
supply voltage at AC maximum rated value		
supply voltage at AC initial value	320 575 V	
supply voltage at AC full-scale value		
wide range input	Yes	
buffering time for rated value of the output current in the event of power failure minimum	20 ms	
operating condition of the mains buffering	at Vin = 400 V	
line frequency	50/60 Hz	
line frequency initial value	47 63 Hz	
line frequency full-scale value		
input current		
• at rated input voltage 400 V	1.6 A	
• at rated input voltage 500 V	1.3 A	
current limitation of inrush current at 25 °C maximum	56 A	
I2t value maximum	2.24 A²·s	
fuse protection type	none	
fuse protection type in the feeder	Required: 3-pole connected miniature circuit breaker 10 16 A characteristic C or circuit breaker 3RV2011-1DA10 (setting 3 A) or 3RV2711-1DD10 (UL 489)	
output		
voltage curve at output	Controlled, isolated DC voltage	
output voltage at DC rated value	24 V	
output voltage		
at output 1 at DC rated value	24 V	
output voltage adjustable	Yes; via potentiometer	
adjustable output voltage initial value	24 V	
adjustable output voltage full-scale value	28.8 V	
relative overall tolerance of the voltage	3 %	
relative control precision of the output voltage		
 on slow fluctuation of input voltage 	0.1 %	
on slow fluctuation of ohm loading	0.1 %	
residual ripple		
• maximum	100 mV	
voltage peak		
• maximum	200 mV	
display version for normal operation	Green LED for 24 V OK	
type of signal at output	Relay contact (NO contact, rating 60 V DC/ 0.3 A) for "24 V OK"	
behavior of the output voltage when switching on	No overshoot of Vout (soft start)	

response delay maximum	2.5 s	
voltage increase time of the output voltage		
maximum	500 ms	
output current		
rated value	30 A	
rated range	0 30 A; +60 +70 °C: Derating 1.7%/K	
supplied active power typical	960 W	
constant overload current		
 on short-circuiting during the start-up typical 	32 A	
at short-circuit during operation typical	32 A	
bridging of equipment	Yes; switchable characteristic	
number of parallel-switched equipment resources for increasing the power	2	
efficiency in percent	93 %	
power loss [W]		
 at rated output voltage for rated value of the output current typical 	50 W	
closed-loop control		
relative control precision of the output voltage with rapid fluctuation of the input voltage by +/- 15% typical	1 %	
relative control precision of the output voltage load step of resistive load 50/100/50 % typical	3 %	
setting time		
• maximum	10 ms	
protection and monitoring		
design of the overvoltage protection	< 35 V	
property of the output short-circuit proof	Yes	
design of short-circuit protection	Alternatively, constant current characteristic approx. 32 A or latching shutdown	
response value current limitation typical	32 A	
enduring short circuit current RMS value		
• typical	32 A	
display version for overload and short circuit	LED yellow for "overload", LED red for "latching shutdown"	
safety		
galvanic isolation between input and output	Yes	
galvanic isolation	Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178	
operating resource protection class	Class I	
leakage current		
• maximum	3.5 mA	
maximum protection class IP	3.5 mA IP20	
protection class IP		
protection class IP standard	IP20	
protection class IP standard • for emitted interference	IP20 EN 55022 Class B EN 61000-3-2	
protection class IP standard • for emitted interference • for mains harmonics limitation • for interference immunity	IP20 EN 55022 Class B	
protection class IP standard • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals	IP20 EN 55022 Class B EN 61000-3-2	
protection class IP standard • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability	IP20 EN 55022 Class B EN 61000-3-2 EN 61000-6-2	
protection class IP standard • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability • CE marking	IP20 EN 55022 Class B EN 61000-3-2 EN 61000-6-2 Yes	
protection class IP standard • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability • CE marking • UL approval	IP20 EN 55022 Class B EN 61000-3-2 EN 61000-6-2 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259	
protection class IP standard • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability • CE marking • UL approval • CSA approval	IP20 EN 55022 Class B EN 61000-3-2 EN 61000-6-2 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259	
protection class IP standard • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability • CE marking • UL approval • CSA approval • EAC approval	IP20 EN 55022 Class B EN 61000-3-2 EN 61000-6-2 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes	
protection class IP standard • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability • CE marking • UL approval • CSA approval • EAC approval • NEC Class 2	IP20 EN 55022 Class B EN 61000-3-2 EN 61000-6-2 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259	
protection class IP standard • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability • CE marking • UL approval • CSA approval • EAC approval • EAC approval • NEC Class 2 type of certification	IP20 EN 55022 Class B EN 61000-3-2 EN 61000-6-2 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes No	
protection class IP standard • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability • CE marking • UL approval • CSA approval • EAC approval • EAC aperoval • NEC Class 2 type of certification • CB-certificate	IP20 EN 55022 Class B EN 61000-3-2 EN 61000-6-2 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes No No	
protection class IP standard • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability • CE marking • UL approval • CSA approval • EAC approval • EAC approval • NEC Class 2 type of certification • CB-certificate MTBF at 40 °C	IP20 EN 55022 Class B EN 61000-3-2 EN 61000-6-2 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes No	
protection class IP standard • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability • CE marking • UL approval • CSA approval • EAC approval • NEC Class 2 type of certification • CB-certificate MTBF at 40 °C standards, specifications, approvals hazardous environments	IP20 EN 55022 Class B EN 61000-3-2 EN 61000-6-2 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes No No	
protection class IP standard • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability • CE marking • UL approval • CSA approval • EAC approval • NEC Class 2 type of certification • CB-certificate MTBF at 40 °C standards, specifications, approvals hazardous environments certificate of suitability	IP20 EN 55022 Class B EN 61000-3-2 EN 61000-6-2 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes No No 885 739 h	
protection class IP standard • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability • CE marking • UL approval • CSA approval • EAC approval • NEC Class 2 type of certification • CB-certificate MTBF at 40 °C standards, specifications, approvals hazardous environments certificate of suitability • IECEx	IP20 EN 55022 Class B EN 61000-3-2 EN 61000-6-2 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes No No No 885 739 h	
protection class IP standard • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability • CE marking • UL approval • CSA approval • EAC approval • NEC Class 2 type of certification • CB-certificate MTBF at 40 °C standards, specifications, approvals hazardous environments certificate of suitability • IECEx • ATEX	IP20 EN 55022 Class B EN 61000-3-2 EN 61000-6-2 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes No No No 885 739 h	
protection class IP standard • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability • CE marking • UL approval • CSA approval • EAC approval • NEC Class 2 type of certification • CB-certificate MTBF at 40 °C standards, specifications, approvals hazardous environments certificate of suitability • IECEx • ATEX • ULhazloc approval	IP20 EN 55022 Class B EN 61000-3-2 EN 61000-6-2 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes No No No 885 739 h No No	
protection class IP standard • for emitted interference • for mains harmonics limitation • for interference immunity standards, specifications, approvals certificate of suitability • CE marking • UL approval • CSA approval • EAC approval • NEC Class 2 type of certification • CB-certificate MTBF at 40 °C standards, specifications, approvals hazardous environments certificate of suitability • IECEX • ATEX	IP20 EN 55022 Class B EN 61000-3-2 EN 61000-6-2 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes No No No 885 739 h	

No No	
No	
No	
No	
No	
-25 +70 °C; with natural convection	
-40 +85 °C	
-40 +85 °C	
Climate class 3K3, 5 95% no condensation	
screw-type terminals	
L1, L2, L3, PE: 1 screw terminal each for 0.2 4 mm² single-core/finely	
stranded	
+, -: 2 screw terminals each for 0.33 10 mm ²	
13, 14 (alarm signal): 1 screw terminal each for 0.14 1.5 mm ²	
150 × 125 × 150 mm	
150 × 225 mm	
50 mm	
50 mm	
0 mm	
0 mm	
Snaps onto DIN rail EN 60715 35x15	
Yes	
No	
No	
Yes	
3.4 kg	
Buffer module	
Device identification label 20 mm × 7 mm, TI-grey 3RT2900-1SB20	
https://siemens.com/tst	
http://www.siemens.com/simatic-net	
http://www.siemens.com/cax	
Specifications at rated input voltage and ambient temperature +25 °C (unless otherwise specified)	
Siemens provides products and solutions with industrial security functions that support the secure operation of plants, systems, machines and networks. In order to protect plants, systems, machines and networks against cyber threats, it is necessary to implement – and continuously maintain – a holistic, state-of-the-art industrial security concept. Siemens' products and solutions constitute one element of such a concept. Customers are responsible for preventing unauthorized access to their plants, systems, machines and networks. Such systems, machines and components should only be connected to an enterprise network or the internet if and to the extent such a connection is necessary and only when appropriate security measures (e.g. firewalls and/or network segmentation) are in place. For additional information on industrial security measures that may be implemented, please visit https://www.siemens.com/industrialsecurity. Siemens' products and solutions undergo continuous development to make them more secure. Siemens strongly recommends that product updates are applied as soon as they are available and that the latest product versions are used. Use of product versions that are no longer supported, and failure to apply the latest updates may increase customer's exposure to cyber threats. To stay informed about product updates, subscribe to the Siemens Industrial Security RSS Feed under https://www.siemens.com/cert. (V4.6)	

	Version	Classification
eClass	12	27-04-07-01
eClass	9.1	27-04-07-01
eClass	9	27-04-07-01
eClass	8	27-04-90-02
eClass	7.1	27-04-90-02
eClass	6	27-04-90-02
ETIM	9	EC002540
ETIM	8	EC002540
ETIM	7	EC002540
IDEA	4	4130
UNSPSC	15	39-12-10-04

Approvals Certificates

General Product Approval

Manufacturer Declaration Declaration of Conformity





last modified: 2/13/2024 🖸